

TEST REPORT

Report No: QMTL/R-366172/2024

| | | | |
|---|-----------------------------|--------------------|---------------------------|
| CLIENT : AABAN BUILDING CLEANING SERVICES Office no 126 Safiya Building Bin Suloom Hor Al Anz Deira, Dubai PO Box : - United Arab Emirates | | Sample ID | QMTL/S-366172 |
| ATTN : JHANZAIB NIZAM | | Date Received | 10 Oct 2024 |
| | | Date(s) Tested | 10 Oct 2024 - 20 Oct 2024 |
| | | Date Reported | 22 Oct 2024 |
| Sample Description | RCC Tank Basement Pump Room | | |
| Sample Type | Water | Sampling Method | QMTL-WI-15 & QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Wise Indian Academy, Ajman | Sampling Date/Time | 10.10.2024/09:40 am |
| Sample Container | 1x1L PB & 1x500 ml PB | Sampling Point | Tank |
| Sample Receipt Temp | 4°C & 21°C | Sample Onsite Temp | 34.8°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|------------|------------|---------|
| MICROBIOLOGICAL PARAMETERS | | | | |
| E.coli* | APHA 9222 H-23rd Edition | CFU/100 ml | Zero | Zero |
| Total Bacterial Count* | APHA 9215 B -23rd Edition | CFU/ml | - | 50 |
| Total Coliforms* | APHA 9222 B -23rd Edition | CFU/100 ml | Zero | Zero |
| LEGIONELLA ANALYSIS | | | | |
| Legionella* | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |


The Analysis results denoted by (*) are part of the laboratory EIAC Accreditation to ISO/IEC 17025 : 2017.

| | |
|---------|---|
| Remarks | The sample meets with Gulf Standard No.149/2021 for un-bottled drinking water with respect to the above tests only. |
|---------|---|

| | |
|----------|---|
| Keywords | CFU:Colony Forming Unit, APHA:American Public Health Association, ISO:International Organization for Standardization, NP:Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE:Buffered Charcoal Yeast Extract, Culture Media. |
|----------|---|

| | |
|---|---------|
| Test method deviation | None |
| Test performed by Emp# | 300&301 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Authorized By



AATISH ANURAG
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

| | | | |
|--|----------------------------|--------------------------------------|---------------------------|
| CLIENT : AABAN BUILDING CLEANING SERVICES Office no 126 Safiya Building Bin Suloom Hor Al Anz Deira, Dubai PO Box : - United Arab Emirates | | Report No: QMTL/R-366168/2024 | |
| ATTN : JHANZAIB NIZAM | | Sample ID | QMTL/S-366168 |
| | | Date Received | 10 Oct 2024 |
| | | Date(s) Tested | 10 Oct 2024 - 20 Oct 2024 |
| | | Date Reported | 22 Oct 2024 |
| Sample Description | Rooftop Tank 1 | | |
| Sample Type | Water | | |
| Client Name/Project | NP | Sampling Method | QMTL-WI-15 & QMTL-WI-16 |
| Location | Wise Indian Academy, Ajman | Sampled By | QMTL Representative |
| Sample Container | 1x1L PB & 1x500 ml PB | Sampling Date/Time | 10.10.2024/09:10 am |
| Sample Receipt Temp | 4°C & 21°C | Sampling Point | Tank |
| Sample Appearance | Clear | Sample Onsite Temp | 35°C |
| Reference | NP | On-site Treatment | NA |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|------------|------------|---------|
| MICROBIOLOGICAL PARAMETERS | | | | |
| E.coli* | APHA 9222 H-23rd Edition | CFU/100 ml | Zero | Zero |
| Total Bacterial Count* | APHA 9215 B -23rd Edition | CFU/ml | - | 52 |
| Total Coliforms* | APHA 9222 B -23rd Edition | CFU/100 ml | Zero | Zero |
| LEGIONELLA ANALYSIS | | | | |
| Legionella* | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |
| The Analysis results denoted by (*) are part of the laboratory EIAC Accreditation to ISO/IEC 17025 : 2017. | | | | |

Remarks: The sample meets with Gulf Standard No.149/2021 for un-bottled drinking water with respect to the above tests only.

| | |
|---|---|
| Keywords | CFU:Colony Forming Unit, APHA:American Public Health Association, ISO:International Organization for Standardization, NP:Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE:Buffered Charcoal Yeast Extract, Culture Media. |
| Test method deviation | None |
| Test performed by Emp# | 300&301 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Authorized By

Aatish

AATISH ANURAG

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

| | | | |
|---|----------------------------|--------------------|---------------------------|
| CLIENT : AABAN BUILDING CLEANING SERVICES Office no 126 Safiya Building Bin Suloom Hor Al Anz Deira, Dubai PO Box : - United Arab Emirates | | Sample ID | QMTL/S-366169 |
| ATTN : JHANZAIB NIZAM | | Date Received | 10 Oct 2024 |
| | | Date(s) Tested | 10 Oct 2024 - 20 Oct 2024 |
| | | Date Reported | 22 Oct 2024 |
| Sample Description | Rooftop Tank 2 | | |
| Sample Type | Water | | |
| Client Name/Project | NP | Sampling Method | QMTL-WI-15 & QMTL-WI-16 |
| Location | Wise Indian Academy, Ajman | Sampled By | QMTL Representative |
| Sample Container | 1x1L PB & 1x500 ml PB | Sampling Date/Time | 10.10.2024/09:10 am |
| Sample Receipt Temp | 4°C & 21°C | Sampling Point | Tank |
| Sample Appearance | Clear | Sample Onsite Temp | 35°C |
| Reference | NP | On-site Treatment | NA |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|------------|------------|---------|
| MICROBIOLOGICAL PARAMETERS | | | | |
| E.coli* | APHA 9222 H-23rd Edition | CFU/100 ml | Zero | Zero |
| Total Bacterial Count* | APHA 9215 B -23rd Edition | CFU/ml | - | 56 |
| Total Coliforms* | APHA 9222 B -23rd Edition | CFU/100 ml | Zero | Zero |
| LEGIONELLA ANALYSIS | | | | |
| Legionella* | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |
| The Analysis results denoted by (*) are part of the laboratory EIAC Accreditation to ISO/IEC 17025 : 2017. | | | | |

| | |
|---|---|
| Remarks | The sample meets with Gulf Standard No.149/2021 for un-bottled drinking water with respect to the above tests only. |
| Keywords | CFU:Colony Forming Unit, APHA:American Public Health Association, ISO:International Organization for Standardization, NP:Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE:Buffered Charcoal Yeast Extract, Culture Media. |
| Test method deviation | None |
| Test performed by Emp# | 300&301 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Authorized By

Aatish

AATISH ANURAG
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

CLIENT : AABAN BUILDING CLEANING SERVICES
Office no 126 Safiya Building Bin Suloom Hor Al Anz Deira, Dubai PO
Box : -
United Arab Emirates

ATTN : JHANZAIB NIZAM

Report No: QMTL/R-366170/2024

| | | | |
|---|----------------------------|--------------------|---------------------------|
| Office no 126 Safiya Building Bin Suloom Hor Al Anz Deira, Dubai PO Box : - United Arab Emirates ATTN : JHANZAIB NIZAM | | Sample ID | QMTL/S-366170 |
| | | Date Received | 10 Oct 2024 |
| | | Date(s) Tested | 10 Oct 2024 - 20 Oct 2024 |
| | | Date Reported | 22 Oct 2024 |
| Sample Description | Rooftop Tank 3 | | |
| Sample Type | Water | | |
| Client Name/Project | NP | Sampling Method | QMTL-WI-15 & QMTL-WI-16 |
| Location | Wise Indian Academy, Ajman | Sampled By | QMTL Representative |
| Sample Container | 1x1L PB & 1x500 ml PB | Sampling Date/Time | 10.10.2024/09:15 am |
| Sample Receipt Temp | 4°C & 21°C | Sampling Point | Tank |
| Sample Appearance | Clear | Sample Onsite Temp | 36°C |
| Reference | NP | On-site Treatment | NA |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|------------|------------|---------|
| MICROBIOLOGICAL PARAMETERS | | | | |
| E.coli* | APHA 9222 H-23rd Edition | CFU/100 ml | Zero | Zero |
| Total Bacterial Count* | APHA 9215 B -23rd Edition | CFU/ml | - | 48 |
| Total Coliforms* | APHA 9222 B -23rd Edition | CFU/100 ml | Zero | Zero |
| LEGIONELLA ANALYSIS | | | | |
| Legionella* | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |
| The Analysis results denoted by (*) are part of the laboratory EIAC Accreditation to ISO/IEC 17025 : 2017. | | | | |

Remarks : The sample meets with Gulf Standard No.149/2021 for un-bottled drinking water with respect to the above tests only.

Keywords : CFU: Colony Forming Unit, APHA: American Public Health Association, ISO: International Organization for Standardization, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media.

| | |
|---|---------|
| Test method deviation | None |
| Test performed by Emp# | 300&301 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Authorized By

Aatish

AATISH ANURAG
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

| | | | |
|---|----------------------------|-------------------------------|---------------------------|
| CLIENT : AABAN BUILDING CLEANING SERVICES Office no 126 Safiya Building Bin Suloom Hor Al Anz Deira, Dubai PO Box : - United Arab Emirates | | Report No: QMTL/R-366171/2024 | |
| ATTN : JHANZAIB NIZAM | | Sample ID | QMTL/S-366171 |
| | | Date Received | 10 Oct 2024 |
| | | Date(s) Tested | 10 Oct 2024 - 20 Oct 2024 |
| | | Date Reported | 22 Oct 2024 |
| Sample Description | Rooftop Tank 4 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-15 & QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Wise Indian Academy, Ajman | Sampling Date/Time | 10.10.2024/09:15 am |
| Sample Container | 1x1L PB & 1x500 ml PB | Sampling Point | Tank |
| Sample Receipt Temp | 4°C & 21°C | Sample Onsite Temp | 35°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| TEST RESULTS | | | | |
|--|---|------------|------------|---------|
| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
| MICROBIOLOGICAL PARAMETERS | | | | |
| E.coli* | APHA 9222 H-23rd Edition | CFU/100 ml | Zero | Zero |
| Total Bacterial Count* | APHA 9215 B -23rd Edition | CFU/ml | - | 45 |
| Total Coliforms* | APHA 9222 B -23rd Edition | CFU/100 ml | Zero | Zero |
| LEGIONELLA ANALYSIS | | | | |
| Legionella* | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |
| The Analysis results denoted by (*) are part of the laboratory EIAC Accreditation to ISO/IEC 17025 : 2017. | | | | |
| Remarks | The sample meets with Gulf Standard No.149/2021 for un-bottled drinking water with respect to the above tests only. | | | |
| Keywords | CFU:Colony Forming Unit, APHA:American Public Health Association, ISO:International Organization for Standardization, NP:Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE:Buffered Charcoal Yeast Extract, Culture Media. | | | |
| Test method deviation | None | | | |
| Test performed by Emp# | 300&301 | | | |
| Report prepared by Emp# | 72 | | | |
| The above test results are only applicable to the sample(s) referred above. | | | | |
| Authorized By: | | | | |

Authorized By

Aatish

AATISH ANURAG

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT